



The Town Council of Centreville

101 Lawyers Row
Centreville, Maryland 21617
410-758-1180
Fax 410-758-4741

Department of Police
Department of Streets
Department of Water and Sewer
Chesterfield Cemetery

August 4, 2004

David J. Pushkar, Division Chief
Maryland Dept. of the Environment
1800 Washington Boulevard
Baltimore, MD 21230

Dear Mr. Pushkar:

The following actions have been taken concerning your letter of July 23, 2004:

Item 1.a. A new bar has been installed and is operating. The Nursing Home and Correction Facility have been contacted concerning the debris problem. If this problem persists the Town will enforce ordinances and levy fines. Alarms have been installed at the North and south Pump Stations and response time is immediate.

Item 1.b. The piping will not come unclogged.

Item 1.f. Chamber was cleaned twice. Flow was calibrated at the time of inspection and was in the proper range of measurement and flow.

Item I & J. Back-up generators have been installed.

Item 2.a. The sampler tube is cleaned every two months.

Item 2.b. Stop time has been added to the Composite Sampler Log. Daily pH, DO and Chlorine are taken every three hours. At the time of the inspection visit, Joe Cherone added acid and demonstrated to Randy Denny, MDE, Dave Bramble, MDE, and David Arnett, EPA sufficiency in the bottles to bring the reading below 2.0 average.

Item 3.a. The Town has resubmitted DMR for April and May.

Item 3.b. Permit No. -04-30-5064-T should include anaerobic sludge. The Town is in the process of hauling anaerobic sludge to reach a shut down status for the old plant. The Town is

David J. Pushkar
August 4, 2004
Page 4

currently hauling 15,000 gal/week and will finish when the new Waste Water Treatment Plant is operational.

Item 3.d. The maintenance Log has been created.

Please let me know if you need any additional information.

Sincerely,


Richard N. Conti
Acting Town Manager

(Pushkar4Aug04.doc0